



August 07, 2017

Bo Stanley
City of Tuscumbia
PO Box 29
Tuscumbia, AL 35674

We appreciate the opportunity to provide our services to you on this project. Please find attached the data for the sample(s) listed below:

<u>LabNumber</u>	<u>Sample Description</u>	<u>Date/Time Collected</u>	<u>Date Submitted</u>
1710509-01	Pipe-1	7/28/17 17:00	7/28/17

ENERSOLV is accredited to ISO/IEC 17025:2005 by Laboratory Accreditation Bureau and to the TNI 2003 Standard by the Florida Department of Health. Our quality system also meets relevant quality system requirements of ISO 9001:2008. Not all tests performed by *ENERSOLV* are covered by these accreditations. Tests within our scope of accreditation are indicated by an asterisk (*) in the Test Result section of this report. Tests not included in the accreditations are performed in accordance with *ENERSOLV* Standard Operating Procedures and the quality control program using, where applicable, USEPA methodology.

This cover page and the attached chain-of-custody record(s) are integral parts of your report. *ENERSOLV* considers this report your official record. This information shall remain in *ENERSOLV*'s active database for a period of one (1) calendar year before archiving. Any replacement of this information after archiving may result in an administrative fee to cover the cost of retrieval.

If you have any questions or would like more information regarding these analyses, please call us at (256) 350-0846.

Karen Sutton
Vice President Client Services



SAMPLE RESULTS REPORT

Report Date/Time: 08/07/2017 17:04

REPORT TO
Bo Stanley City of Tuscumbia PO Box 29 Tuscumbia, AL 35674



NELAP
Accredited
Florida DOH
#E871078

ENERSOLV maintains National Environmental Laboratory Accreditation Program (NELAP) accreditation through Florida Department of Health (#E871078). Some tests included in this report may not be covered by this accreditation.

ENERSOLV also maintains ISO/IEC 17025 accreditation through Laboratory Accreditation Bureau for the specific tests listed in L-A-B Certificate #L2239 scope of accreditation.

Tests within the scope of accreditation are indicated by an asterisk (*).

This report may contain information that is confidential and/or proprietary. This information is intended for the addressee only and may not be copied or disseminated except in full without the written consent of ENERSOLV Corporation.



Cert# L2239 Testing

ADEM
Drinking Water
Certification
No. 40160

Analyte Name	Result	Units	Qual	Regulatory Limit
--------------	--------	-------	------	------------------

Sample Point: Pipe-1

Sample ID: 1710509-01

Collected: 07/28/2017

Submitted: 07/28/2017

Inorganics

- * HEM (Oil and Grease)
- * Total Suspended Solids

	<5.00	mg/l
	<2.50	mg/l

On-Site Analysis

- * pH

	8.1	su
--	-----	----



SAMPLE RESULTS REPORT

Report Date/Time: 08/07/2017 17:04

REPORT TO
Bo Stanley City of Tuscumbia PO Box 29 Tuscumbia, AL 35674



NELAP
Accredited
Florida DOH
#E871078

ENERSOLV maintains National Environmental Laboratory Accreditation Program (NELAP) accreditation through Florida Department of Health (#E871078). Some tests included in this report may not be covered by this accreditation.

ENERSOLV also maintains ISO/IEC 17025 accreditation through Laboratory Accreditation Bureau for the specific tests listed in L-A-B Certificate #L2239 scope of accreditation.

Tests within the scope of accreditation are indicated by an asterisk (*).

This report may contain information that is confidential and/or proprietary. This information is intended for the addressee only and may not be copied or disseminated except in full without the written consent of ENERSOLV Corporation.



Cert# L2239 Testing

ADEM
Drinking Water
Certification
No. 40160

All calculations are performed prior to rounding per EPA and *Standard Methods* requirements.

Data Qualifiers:

< Less than reporting limit

Analysis Information

Lab Number	Analysis	SpecificMethod	Analyst	Analysis Start Date/Time	Analysis End Date/Time
1710509-01	HEM (Oil and Grease)	EPA 1664A	JG	08/03/2017 10:30	
1710509-01	Total Suspended Solids	USGS I-3765-85	SH	08/01/2017 13:25	

The results contained in this report are only representative of the sample(s) received.



ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD
 2220 BELTLINE ROAD SW DECATUR, ALABAMA 35601
 (256) 350-0846

www.enersolv.com

COMPANY/CLIENT NAME City of Tuscumbia		CLIENT P.O. NUMBER ENE 13502 RMCWHORTER		REQUESTED ANALYSES			
CLIENT POINT OF CONTACT Bo Stanley		CLIENT PHYSICAL ADDRESS 202 East 6th Street					
CLIENT EMAIL bostan29@comcast.net		PHONE NUMBER (256)386-5674		OTHER INFORMATION			
SAMPLE COLLECTED BY <i>R. McWhorter</i>		EXPEDITED REPORT DELIVERY (SURCHARGE)		DATE DUE (REQUIRED)			
ENERSOLV LAB NUMBER	SAMPLE DESCRIPTION	SAMPLE TRANSFER/GRAB DATE	SAMPLE TRANSFER/GRAB TIME	GRAB COMP	G	TSS	H
1710509-01	PIPE-1	7/28/17	17:20	X	X	X	X
	PIPE-2	ND		X	X	X	X
	PIPE-3	ND					
	PIPE-4	ND					
	PIPE-5	ND					
	PIPE-6	ND					

Comments:

Collector to complete shaded areas, as applicable

SAMPLE TEMPERATURE RECEIVED @ *8:45*

SAMPLER INFORMATION		FIELD INFORMATION						Qty	Type	Parameters
Start Date	pH su	TRC mg/l	DO mg/l	Temp deg C	Date	Analyst	2	Glass WM 1000ml HCL Cool 6c	OG	
Start Time	Date	Date	Date	Date	Date	Analyst	1	Poly Qrt Cool 6c	TSS	
Stop Date	Time	Analyst	Analyst	Analyst	Analyst	Analyst				
Stop Time	Analyst	SM 4500H+B	SM 4500-CID	SM 4500-O G	SM 2550B					
RELINQUISHED BY: (SIGNATURE)		DATE	TIME	RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RELINQUISHED BY: (SIGNATURE)	DATE	TIME	
<i>[Signature]</i>		7/28/17	20:50	<i>[Signature]</i>			<i>[Signature]</i>			
RECEIVED BY: (SIGNATURE)		DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME	
<i>[Signature]</i>		7/28/17	20:50	<i>[Signature]</i>			<i>[Signature]</i>			
RECEIVED FOR LABORATORY USE BY: (SIGNATURE)		DATE	TIME	SAMPLE STATUS						
<i>[Signature]</i>		7/28/17	20:50	Accepted						

Rejected Accepted Accepted with Exception

Energolv Field Calibration Record

Calibrated By: R. White Date: 7/28/17 Time: 1547

pH Meter Calibration - Equipment number: PH 303

	7.00 pH buffer	10.00pH buffer	Acceptance Criteria met?	
	Acc. Range 7.0 +/- 0.1	Acc. Range 10.0 +/- 0.1	Yes	No
Value before calibration, s.n.	6.9	10.09	Yes	No
Buffer Temp. before calibration, °C	25.0	25.0		
Value after calibration, s.n.	7.00	10.0		
Buffer Temp. after calibration, °C	25.0	25.0		
Reagent Number - Pre-calibration	EG 71208	EG 2104		
Reagent Number - Post-calibration	EG 71208	EG 2104		

pH Meter Post Cal. Date: 7/28/17 Time: 20:45 4.0 Buffer Cal., if required Date/time: _____ NA

	7.00 pH buffer	10.0 pH buffer	4.00 pH buffer	
	Acc. range 7.00 +/- 0.2	Acc. Range 10.00 +/- 0.2	Acc. Range 4.00 +/- 0.1	
Value, s.n.	7.03	9.99		
Buffer Temp. °C	25.0	25.0		
Reagent Number	EG 71208	EG 2104	Pre	Post

Dissolved Oxygen Meter - Equipment Number: _____ NA

	Oxygen meter reading	Calibration successful?	
		Yes	No
Value before calibration, mg/L			
% Air Saturation / Slope			
Value after calibration, mg/L			

Turbidity Meter - Equipment number: 150

NA

	1 NTU	10 NTU
Meter Reading Before Calibration, NTU		
Meter Reading After Calibration, NTU		
Turbidity Standard Reagent Number		

Conductivity Meter - Equipment Number: _____

NA

Value of Conductivity Standard, uS	
Meter reading before calibration, uS	
Cell Constant Value	
Conductivity Standard Reagent Number	

Residual Chlorine Meter - Equipment Number: _____

NA

Reagent numbers - Phenylarsine oxide (free & total) R- _____ pH 7 buffer (free) R- _____

pH 4 buffer (total) R- _____ Potassium iodide (total) _____ KMnO₄ LCS: S- _____

Circuit check (check one): OK _____ Needs Attention _____

KMnO₄ LCS, mg/L Acceptance Limits 0.24 - 0.26mg/L Before _____ After _____

DPD Total Chlorine Reagent Pillows: R- _____

Hach DPD Standard Lot no. _____ Before: STD 1 _____ STD 2 _____ STD 3 _____

After: STD 1 _____ STD 2 _____ STD 3 _____

Cal check acceptance limits: (0.13 - 0.31) (0.75 - 0.95) (1.37 - 1.65)

For all field instruments: Calibration/Confirmation Interval: Prior to each use, but not more than daily
 Calibration Environmental Conditions: Room temperature

Note: If equipment calibration fails to meet acceptance limits, the equipment must be taken out of service and tagged for repair.